To: Hopkins, Ingrid[Hopkins.Ingrid@epa.gov]

From: Hopkins, Ingrid

Sent: Wed 9/9/2015 3:27:08 PM

Subject: Fw: Washington Aqueduct Site Inspection of Sedimentation Basin Bypass

Washington Aqueduct Site Inspection Photos 12.01.14.pdf

Washington Aqueduct Site Inspection 12.02.14.pdf
Aquaduct Field Notes 12.01.2014 12.02.2014 DVP.pdf

Washington Aqueduct Sediment Basin Discharge Inspection Report 12.02.14.pdf

Ingrid H. Hopkins NPDES Enforcement Branch (3WP42) U.S. EPA, Region III 1650 Arch Street Philadelphia, PA 19103 Comm: (215) 814-5437

From: Rodriguez, Joshua (DDOE) <joshua.rodriguez@dc.gov>

Sent: Tuesday, December 2, 2014 5:43 PM **To:** Price-Fay, Michelle; Hopkins, Ingrid

Cc: Seligman, Andrew; Bendik, Kaitlyn; Kelley, Isaac (DDOE); Pilat, David (DDOE) **Subject:** Washington Aqueduct Site Inspection of Sedimentation Basin Bypass

Michelle,

Attached are the findings of our inspections of the Washington Aqueduct in response to their request and subsequent approval for the bypass and discharge of their sedimentation basins. DDOE WQD Inspection and Enforcement recommends the discharge and bypass authorization be immediately suspended and the discharge from the Georgetown Reservoir's Outfalls 003 and 004 cease, while the process by which the Aqueduct handles the sediment and residual solids is re-evaluated.

If you have further questions please do not hesitate to contact me.

Thank you.

Joshua Rodriguez

Branch Chief

Inspection and Enforcement Branch

Water Quality Division

District Department of the Environment

1200 First Street, NE, 5th floor

Washington, DC 20002

Joshua.Rodriguez@DC.Gov

(202) 805-1356 Mobile

(202) 535-2226 Direct

(202) 535-2600 Main

green.dc.gov



STATEMENT OF CONFIDENTIALITY The information contained in this electronic message and any attachments to it are intended for the exclusive use of the addressee(s) and may contain confidential or privileged information. If you are not the intended recipient, please notify the sender immediately and destroy all copies of this message and any attachments.